

The Corporation of The

Town of Amherstburg

Fire Department



STR FIRE SAFETY CHECKLIST

ALL SHORT TERM RENTALS REQUIRE MAINTENANCE DOCUMENTATION **Ongoing 2 Year Records Upon Request** ٠ INTERCONNECTED SMOKE ALARMS All Levels • Each Bedroom Dedicated Service Room CARBON MONOXIDE ALARMS OUTSIDE ALL SLEEPING AREAS Outside All Sleeping Areas if Building has Attached Garage and/or Fuel Burning Appliances 2A10BC EXTINGUISHER All Levels at Exits • FIREPLACE/CHIMNEY/APPLIANCES ANNUAL MAINTENANCE All Fuel Burning Appliances; Furnace, Hot Water, Fireplace, Wood Stove • Fire Department Maintenance Requirement Sign Off ٠ MAINTENANCE OF EXITS All Exits • • Signage Over Each Exit Exits Are Unobstructed Inside and Outside The Suite Emergency Window Exits Shall Have Window Opening Instructions Posted At The Window **APPROVED FIRE SAFETY PLAN (FSP)** • Required for Each Unit and Must be Submitted to Fire Service for Review and Approval

• FSP Must Include Floor Plans for Each Level and Parking Plan if Applicable

Michael Mio Fire Chief PRESERVING OUR PAST – PROTECTING OUR FUTURE
 Phone:
 519-736-6500

 Fax:
 519-736-3683

 Email: mmio@amherstburg.ca

FLOOR PLA	INS
• Approved	 Floor Plans for Each Level - Must Have a Legend and Indicates Placement of: a. Smoke/Carbon Monoxide Alarms b. Smoke Alarms c. Fire Extinguishers d. EXIT Signs & Emergency Lighting e. Secondary Means of Egress f. Main Electrical Shut Off g. Main Gas Shut Off h. Mechanical Room Location DSECOND EXIT BASEMENT
•	Approved Second Exit from Basement if Sleeping Below Grade
	i. Basement Y/N
SHORT T	ERM RENTALS 5 BEDROOMS OR GREATER ALSO REQUIRE
EMERGEN	CY CORRIDOR LIGHTING
•	All Corridors
•	Stairways
APPROVED	SECOND EXIT
•	Approved Second Exit from: i. First Floor Y/N ii. Second Floor Y/N iii. Third Floor Y/N
EXIT SIGN	AGE
•	All Corridors (Exit sign meets OBC requirements for size, colour and either hardwired or photoluminescent Ensure the exit signage meets CAN/ULC S-572 Standard for Photoluminescen
	signage
SHORT T	ERM RENTALS 7 BEDROOMS OR GREATER ALSO REQUIRE
FIRE ALAR	M SYSTEM
•	All Corridors (Exit sign meets OBC requirements for size, colour and either hardwired or photoluminescent (photoluminescent also requires constant light source or emergency light pack directed at sign))
•	Ensure the exit signage meets CAN/ULC S-572 Standard for Photoluminescent signage