

## Drinking Water Systems Regulation O. Reg. 170/03 Section 11 Annual Report

Drinking-Water System Number:	210000149
Drinking-Water System Name:	Amherstburg Water Treatment Plant
Drinking-Water System Owner:	Corporation of the Town of Amherstburg
Drinking-Water System Operating Authority:	Ontario Clean Water Agency
Drinking-Water System Category:	Large municipal residential system
Period being reported:	January 1, 2024 to December 31, 2024

**Complete if your Category is Large Municipal Residential or Small Municipal Residential**

Does your Drinking-Water System serve more than 10,000 people?

Yes ☒ No ☐

Is your annual report available to the public at no charge on a web site on the Internet?

Yes ☒ No ☐

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Amherstburg Area Water Treatment Plant  
 415 Front Road North  
 Amherstburg, Ontario, N9V 2V5

**Complete for all other Categories**

Number of Designated Facilities served:

N/A

Did you provide a copy of your annual report to all Designated Facilities you serve?

N/A

Number of Interested Authorities you report to:

N/A

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?

N/A

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes ☒ No ☐

Indicate how you notified system users that your annual report is available, and is free of charge.

<input checked="" type="checkbox"/> Public access/notice via the web
<input type="checkbox"/> Public access/notice via Government Office
<input type="checkbox"/> Public access/notice via a newspaper
<input type="checkbox"/> Public access/notice via Public Request
<input type="checkbox"/> Public access/notice via a Public Library
<input type="checkbox"/> Public access/notice via other method _____

### Describe your Drinking-Water System

<b>A surface water treatment plant, rated capacity of 18,184 m<sup>3</sup>/day, consisting of:</b>
An intake crib 155 meters into the Detroit River and connected through a 900mm pipe to the Low Lift Pumping Station.
A low lift pumping station equipped with wet well, three vertical turbine pumps, a coarse bar screen, an automatic traveling screen and two 50mm chlorine solution feed lines and a chlorine diffuser.
A solids-contact upflow clarifier with overflow chamber, chemical feed line, sludge blow off line, sludge scraper and recirculation system.
Four rapid sand filters with dual media of anthracite and silica sand including a backwash system.
A filter effluent clearwell with transfer conduit to the reservoir.
A 14,900m <sup>3</sup> underground storage reservoir.
A high lift pumping station equipped with three vertical turbine pumps, a chlorine solution feed line/diffuser and a filter backwash pump.

### List all water treatment chemicals used over this reporting period

Aluminum Sulphate	CAT-FLOC 8103 Plus
Powdered Activated Carbon	Chlorine Gas
NORFLOC 122	Sodium Bisulphate
Sodium Hypochlorite	

### Were any significant expenses incurred to?

<input checked="" type="checkbox"/> Install required equipment
<input checked="" type="checkbox"/> Repair required equipment
<input checked="" type="checkbox"/> Replace required equipment

### Please provide a brief description and a breakdown of monetary expenses incurred

Installations	Expense
Emergency Chlorine Shutoff System	\$39,487.97
Low Lift Pump	\$30,171.84
Security System	\$5,149.01
Air Relief Valves	\$1,385.97

Inspection, Audits and Calibrations	Expense
Intake Inspection	\$7,123.20
Water Tower Inspection	\$3,561.60
Drinking Water Quality Management Audits	\$3,358.08
Lifting Devices Inspection	\$1,738.26
Compressor Inspection	\$1,560.33
Electrical Safety Inspection	\$1,471.96
Instrumentation Calibration	\$1,438.89
Heater Inspection	\$1,117.32
Emergency Power Inspection	\$1,004.41
Repairs	Expense
Chlorine Gas Feed System	\$5,509.77
Powdered Activated Carbon Feed System	\$2,798.40
Roof Drain	\$2,394.79
Polymer System	\$1,802.54
Air Relief Valve	\$1,191.61
Monorail Hoist	\$1,141.52
Replacements	Expense
Travelling Screen	\$474,696.71
Filter Media	\$16,174.75
Emergency Power Breaker	\$14,737.65
Backflow Preventers and associated valves	\$14,081.80
Heater Motors	\$2,781.10
Filter Drain Valve Limit Switches	\$2,768.20
Process Water Valve	\$1,975.16
Hot Water Tank	\$1,521.31

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Location	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
January 16, 2024	Distribution	Total Coliform	53	cfu 100/mL	Resample	January 19, 2024
October 3, 2024	Treated Water	Clostridium	1	cfu/L	Resample	October 7, 2024

**Microbiological testing done under Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period**

	No. of Samples Collected for period being reported	Range of E.Coli Or Fecal Results		Range of Total Coliform Results		Number of HPC Samples	Range of HPC Results	
		Minimum #	Maximum #	Minimum #	Maximum #		Minimum #	Maximum #
Raw Water	53	20	2000	100	54000	0		
Treated Water	53	0	0	0	0	53	10	10
Distribution Water	478	0	0	0	53	220	10	40

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report**

Parameter & Location	No. of Samples Collected for period being reported	Range of Results	
		Minimum	Maximum
Turbidity, In-House (NTU) - RW	366	2.4	113.4
Turbidity, In-House (NTU) - TW	366	0.01	0.51
Turbidity, On-Line (NTU) - Filt1	8760	0.01	1.55
Turbidity, On-Line (NTU) - Filt2	8760	0.017	1.849
Turbidity, On-Line (NTU) - Filt3	8760	0.002	2.005
Turbidity, On-Line (NTU) - Filt4	8760	0.001	2.006
Free Chlorine Residual, On-Line (mg/L) - TW	8760	0.76	1.7
Free Chlorine Residual, On-Line (mg/L) - Pre	8760	0.76	3.26

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Location & Parameter	Date Sampled	Result	Unit of Measure
License Number 026-101	<b>Filter Backwash</b>			
	Suspended Solids	Jan-02-2024	132	mg/L
	Free Chlorine		0.03	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Jan-02-2024	2160	mg/L
	Free Chlorine		0.01	
	<b>Filter Backwash</b>			
	Suspended Solids	Feb-05-2024	1890	mg/L
	Free Chlorine		0.16	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Feb-05-2024	7730	mg/L
	Free Chlorine		0.05	

<p>Issued on 2023/09/07</p> <p>Environmental Discharge</p>	<b>Filter Backwash</b>			
	Suspended Solids	Mar-12-2024	180	mg/L
	Free Chlorine		0.32	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Mar-12-2024	6860	mg/L
	Free Chlorine		0.01	
	<b>Filter Backwash</b>			
	Suspended Solids	Apr-02-2024	2030	mg/L
	Free Chlorine		0.09	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Apr-02-2024	4030	mg/L
	Free Chlorine		0.01	
	<b>Filter Backwash</b>			
	Suspended Solids	May-07-2024	715	mg/L
	Free Chlorine		0.14	
	<b>Clarifier Discharge</b>			
	Suspended Solids	May-07-2024	5680	mg/L
	Free Chlorine		0.03	
	<b>Filter Backwash</b>			
	Suspended Solids	June-03-2024	1880	mg/L
	Free Chlorine		0.03	
	<b>Clarifier Discharge</b>			
	Suspended Solids	June-03-2024	3490	mg/L
	Free Chlorine		0.03	
	<b>Filter Backwash</b>			
	Suspended Solids	July-03-2024	4810	mg/L
	Free Chlorine		0.10	
	<b>Clarifier Discharge</b>			
	Suspended Solids	July-03-2024	1920	mg/L
	Free Chlorine		0.03	
	<b>Filter Backwash</b>			
	Suspended Solids	Aug-05-2024	746	mg/L
	Free Chlorine		0.05	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Aug-05-2024	3780	mg/L
	Free Chlorine		0.01	
	<b>Filter Backwash</b>			
	Suspended Solids	Sept-02-2024	177	mg/L
	Free Chlorine		0.05	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Sept-02-2024	4160	mg/L
	Free Chlorine		0.04	
	<b>Filter Backwash</b>			
	Suspended Solids	Oct-07-2024	2130	mg/L
	Free Chlorine		0.05	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Oct-07-2024	3890	mg/L
	Free Chlorine		0.03	

	<b>Filter Backwash</b>			
	Suspended Solids	Nov-04-2024	3640	mg/L
	Free Chlorine		0.03	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Nov-04-2024	2240	mg/L
	Free Chlorine		0.03	
	<b>Filter Backwash</b>			
	Suspended Solids	Dec-02-2024	1670	mg/L
	Free Chlorine		0.50	
	<b>Clarifier Discharge</b>			
	Suspended Solids	Dec-02-2024	2180	mg/L
	Free Chlorine		0.08	

Date of legal instrument issued	Location	Date Sampled	Result	Unit of Measure
License Number 026-101 Issued on 2023/09/07  Microcystin	Raw Water	June-01-24	<0.15	µg/l
		June-08-24	<0.15	
		June-15-24	<0.15	
		June-22-24	<0.15	
		June-29-24	<0.15	
		July-06-24	<0.15	
		July-14-24	<0.15	
		July-20-24	<0.15	
		July-27-24	0.16	
		August-03-24	0.36	
		August-10-24	4.88	
		August-17-24	0.56	
		August-24-24	2.18	
		September-01-24	0.32	
		September-07-24	0.55	
		September-14-24	<0.15	
		September-21-24	<0.15	
		September-29-24	<0.15	
		October-05-24	0.22	
		October-13-24	<0.15	
		October-19-24	<0.15	
		October-26-24	<0.15	
	Treated Water	June-03-24	<0.15	µg/l
		June-10-24	<0.15	
		June-17-24	<0.15	
		June-24-24	<0.15	
		July-02-24	<0.15	
		July-08-24	<0.15	
		July-15-24	<0.15	
		July-22-24	<0.15	
		July-29-24	<0.15	

	August-05-24	<0.15
	August-12-24	<0.15
	August-19-24	<0.15
	August-26-24	<0.15
	September-03-24	<0.15
	September-09-24	<0.15
	September-16-24	<0.15
	September-23-24	<0.15
	October-01-24	<0.15
	October-07-24	<0.15
	October-21-24	<0.15
	October-28-24	<0.15

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances MAC	1/2 MAC
Antimony: Sb (ug/L) - TW	2024/08/14	<MDL 0.6	6.0	No	No
Arsenic: As (ug/L) - TW	2024/08/14	0.4	10.0	No	No
Barium: Ba (ug/L) - TW	2024/08/14	16.5	1000.0	No	No
Boron: B (ug/L) - TW	2024/08/14	19.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW	2024/08/14	0.003	5.0	No	No
Chromium: Cr (ug/L) - TW	2024/08/14	0.25	50.0	No	No
Mercury: Hg (ug/L) - TW	2024/08/14	<MDL 0.01	1.0	No	No
Selenium: Se (ug/L) - TW	2024/08/14	0.1	50.0	No	No
Uranium: U (ug/L) - TW	2024/08/14	0.034	20.0	No	No

Additional Inorganics	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances MAC	1/2 MAC
Fluoride (mg/L) - TW	2024/08/14	0.09	1.5	No	No
Nitrite (mg/L) - TW	2024/01/08	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2024/04/09	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2024/07/09	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2024/10/15	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW	2024/01/08	0.585	10.0	No	No
Nitrate (mg/L) - TW	2024/04/09	0.661	10.0	No	No
Nitrate (mg/L) - TW	2024/07/09	0.232	10.0	No	No
Nitrate (mg/L) - TW	2024/10/15	0.207	10.0	No	No
Sodium: Na (mg/L) - TW	2024/08/14	7.5	20*	No	No

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Results		MAC	No. Exceeded
		Minimum	Maximum		
Distribution Water - Lead Results (ug/L)	9	0.17	0.83	10	0
Distribution Water - Alkalinity (mg/L)	8	66	80	n/a	n/a
Distribution Water – pH Field	8	6.98	7.27	n/a	n/a



**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Alachlor (ug/L) - TW	2024/08/14	<MDL 0.02	5.0	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2024/08/14	0.08	5.0	No	No
Azinphos-methyl (ug/L) - TW	2024/08/14	<MDL 0.05	20.0	No	No
Benzene (ug/L) - TW	2024/08/14	<MDL 0.32	1.0	No	No
Benzo(a)pyrene (ug/L) - TW	2024/08/14	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW	2024/08/14	<MDL 0.33	5.0	No	No
Carbaryl (ug/L) - TW	2024/08/14	<MDL 0.05	90.0	No	No
Carbofuran (ug/L) - TW	2024/08/14	<MDL 0.01	90.0	No	No
Carbon Tetrachloride (ug/L) - TW	2024/08/14	<MDL 0.17	2.0	No	No
Chlorpyrifos (ug/L) - TW	2024/08/14	<MDL 0.02	90.0	No	No
Diazinon (ug/L) - TW	2024/08/14	<MDL 0.02	20.0	No	No
Dicamba (ug/L) - TW	2024/08/14	<MDL 0.2	120.0	No	No
1,2-Dichlorobenzene (ug/L) - TW	2024/08/14	<MDL 0.41	200.0	No	No
1,4-Dichlorobenzene (ug/L) - TW	2024/08/14	<MDL 0.36	5.0	No	No
1,2-Dichloroethane (ug/L) - TW	2024/08/14	<MDL 0.35	5.0	No	No
1,1-Dichloroethylene (ug/L) - TW	2024/08/14	<MDL 0.33	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW	2024/08/14	<MDL 0.35	50.0	No	No
2,4-Dichlorophenol (ug/L) - TW	2024/08/14	<MDL 0.15	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW	2024/08/14	<MDL 0.19	100.0	No	No
Diclofop-methyl (ug/L) - TW	2024/08/14	<MDL 0.4	9.0	No	No
Dimethoate (ug/L) - TW	2024/08/14	<MDL 0.06	20.0	No	No
Diquat (ug/L) - TW	2024/08/14	<MDL 1.0	70.0	No	No
Diuron (ug/L) - TW	2024/08/14	<MDL 0.03	150.0	No	No
Glyphosate (ug/L) - TW	2024/08/14	<MDL 1.0	280.0	No	No
Malathion (ug/L) - TW	2024/08/14	<MDL 0.02	190.0	No	No
Metolachlor (ug/L) - TW	2024/08/14	0.06	50.0	No	No
Metribuzin (ug/L) - TW	2024/08/14	<MDL 0.02	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW	2024/08/14	<MDL 0.3	80.0	No	No
Paraquat (ug/L) - TW	2024/08/14	<MDL 1.0	10.0	No	No
PCB (ug/L) - TW	2024/08/14	<MDL 0.04	3.0	No	No
Pentachlorophenol (ug/L) - TW	2024/08/14	<MDL 0.15	60.0	No	No
Phorate (ug/L) - TW	2024/08/14	<MDL 0.01	2.0	No	No
Picloram (ug/L) - TW	2024/08/14	<MDL 1.0	190.0	No	No
Prometryne (ug/L) - TW	2024/08/14	<MDL 0.03	1.0	No	No
Simazine (ug/L) - TW	2024/08/14	<MDL 0.01	10.0	No	No

Terbufos (ug/L) - TW	2024/08/14	<MDL 0.01	1.0	No	No
Tetrachloroethylene (ug/L) - TW	2024/08/14	<MDL 0.35	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2024/08/14	<MDL 0.2	100.0	No	No
Triallate (ug/L) - TW	2024/08/14	<MDL 0.01	230.0	No	No
Trichloroethylene (ug/L) - TW	2024/08/14	<MDL 0.44	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW	2024/08/14	<MDL 0.25	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L)	2024/08/14	<MDL 0.12	100.0	No	No
Trifluralin (ug/L) - TW	2024/08/14	<MDL 0.02	45.0	No	No
Vinyl Chloride (ug/L) - TW	2024/08/14	<MDL 0.17	1.0	No	No

Distribution Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Trihalomethane: Total (ug/L) Annual Average - DW	2024/01/01	28.75	100.0	No	No
HAA Total (ug/L) Annual Average - DW	2024/01/01	10.45	80.0	No	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
None			